



Plan View Drawing CWV350



NOTE:  
 1. EQUIPMENT IS FITTED WITH AN INTERNAL TEMPERATURE & PRESSURE RELIEF VALVE (WATER).  
 2. LOCAL CODE MAY REQUIRE THE DISCHARGE TO BE COLLECTED AND PIPED.  
 3. UNIT SHALL BE INSTALLED AT HEIGHT SUCH THAT EVAPORATOR COIL IS 3'-12" (365) ABOVE MAXIMUM EXPECTED SNOW LOAD.